

APPENDIX E – FULL-LOAD EFFICIENCIES

Opportunities for energy savings may exist by replacing existing monitors with energy efficient ones. NEMA has defined standards of both open and enclosed EE motors. The following Table shows nominal and minimal efficiencies for motors termed, “energy efficient” or “high efficiency”. Their values are somewhat lower that what is really available.

HP	2 POLE		4 POLE		6 POLE		8 POLE	
	Nominal Efficiency	Minimal Efficiency	Nominal Efficiency	Minimal Efficiency	Nominal Efficiency	Minimal Efficiency	Nominal Efficiency	Minimal Efficiency
OPEN MOTORS								
1.0	—	—	82.5	80.0	77.0	74.0	72.0	68.0
1.5	80.0	77.0	82.5	80.0	82.5	80.0	75.5	72.0
2.0	82.5	80.0	82.5	80.0	84.0	81.5	85.5	82.5
3.0	82.5	80.0	86.5	84.0	85.5	82.5	86.5	84.0
5.0	85.5	82.5	86.5	84.0	86.5	84.0	87.5	85.5
7.5	85.5	82.5	88.5	86.5	88.5	86.5	88.5	86.5
10.0	87.5	85.5	88.5	86.5	90.2	88.5	89.5	87.5
15.0	89.5	87.5	90.2	88.5	89.5	87.5	89.5	87.5
20.0	90.2	88.5	91.0	89.5	90.2	88.5	90.2	88.5
25.0	91.0	89.5	91.7	90.2	91.0	89.5	90.2	88.5
30.0	91.0	89.5	91.7	90.2	91.7	90.2	91.0	89.5
40.0	91.7	90.2	92.4	91.0	91.7	90.2	90.2	88.5
50.0	91.7	90.2	92.4	91.0	91.7	90.2	91.7	90.2
60.0	93.0	91.7	93.0	91.7	92.4	91.0	92.4	91.0
75.0	93.0	91.7	93.6	92.4	93.0	91.7	93.6	92.4
100.0	93.0	91.7	93.6	92.4	93.6	92.4	93.6	92.4
125.0	93.0	91.7	93.6	92.4	93.6	92.4	93.6	92.4
150.0	93.6	92.4	94.1	93.0	93.6	92.4	93.6	92.4
200.0	93.6	92.4	94.1	93.0	94.1	93.0	93.6	92.4
ENCLOSED MOTORS								
1.0	—	—	80.0	77.0	75.5	72.0	72.0	68.0
1.5	78.5	75.5	81.5	78.5	82.5	80.0	75.5	72.0
2.0	81.5	78.5	82.5	80.0	82.5	80.0	82.5	80.0
3.0	82.5	80.0	84.0	81.5	84.0	81.5	81.5	78.5
5.0	85.5	82.5	85.5	82.5	85.5	82.5	84.0	81.5
7.5	85.5	82.5	87.5	85.5	87.5	85.5	85.5	82.5
10.0	87.5	85.5	87.5	85.5	87.5	85.5	87.5	85.5
15.0	87.5	85.5	88.5	86.5	89.5	87.5	88.5	86.5
20.0	88.5	86.5	90.2	88.5	89.5	87.5	89.5	87.5
25.0	89.5	87.5	91.0	89.5	90.2	88.5	89.5	87.5
30.0	89.5	87.5	91.0	89.5	91.0	89.5	90.2	88.5
40.0	90.2	88.5	91.7	90.2	91.7	90.2	90.2	88.5
50.0	90.2	88.5	92.4	91.0	91.7	90.2	91.0	89.5
60.0	91.7	90.2	91.7	90.2	91.7	90.2	93.0	91.7
75.0	92.4	91.0	93.0	91.7	93.0	91.7	93.0	91.7
100.0	93.0	91.7	93.6	92.4	93.0	91.7	93.0	91.7
125.0	93.0	91.7	93.6	92.4	93.0	91.7	93.6	92.4
150.0	93.0	91.7	94.1	93.0	94.1	93.0	93.6	92.4
200.0	94.1	93.0	94.5	93.6	94.1	93.0	94.1	93.0

Energy Auditor/Technical Assistance Analysis Training Manual, State Energy Office, State of Florida.